

2020 PFAS Water Sampling Project

Colorado faces an emerging public health challenge from a group of chemicals scientifically called Polyfluroalkyl Substances or “PFAS”. These chemicals are found in toxic firefighting foam, coating additives, surface protection and other consumer products. To help communities learn if their residents are at risk, the Colorado Department of Public Health and Environment offered free testing to public drinking water systems.

The maximum contaminant level for PFAS and PFOA combined are 70 parts per trillion. Prairie View POA water sample test results are:

PFAS 1.95 parts per trillion

PFAS and PFOA combined 0.55 parts per trillion

These results for Prairie View POA show minimal amounts of these substances in the water system and pose no threat to our residents. More information can be found at [epa.gov/pfas](https://www.epa.gov/pfas).